

Xiamen Zhongjingtai Building
Materials Co.,Ltd

Date : 01/02/2018
Our ref. : CWE 01
Your ref.: C.H.

Unit 2A-D,
Lianchang Building, No. 6-8, Huli
Avenue,
Huli District, Xiamen, Fujian
361006

Ref : AK Certificate of Conformity

Type of Equipment : EPS cement sandwich panel
Model Designation : See Certificate
Certificate No. : AK 50399312 0001
Report No. : 15107606 001

Dear Ladies and Gentlemen,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Ming Shan 

CC: Xiamen Zhongjingtai Building Materi

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

CERTIFICATE of Conformity



Registration No.: AK 50399312 0001

Report No.: 15107606 001

Holder: Xiamen Zhongjingtai Building Materials Co.,Ltd
Unit 2A-D,
Lianchang Building, No. 6-8, Huli Avenue,
Huli District, Xiamen, Fujian 361006
P. R. China

Product: Partition Wall
EPS cement sandwich panel

Identification: Type No : ZJT
Thickness : 100 mm
Area Weight: 66 kg/m²
Serial No. : ZJT-001

Remark:

1. The test result is: Non-combustible materials.
2. Refer to test report 15107606 001 for details.

Tested acc. to: BS 476-4:1970

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date 01.02.2018



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg